

I N T E R
O F F I C E

MEMO

To: RANDY LYMAN
From: Gene Pabst *GP*
Subject: Consumers Market, 1730 S. Campbell.
Date: January 29, 1998

I did an inspection (01-29-98, 10:30 A.M.) at Consumers Market, 1730 S. Campbell, to determine if they have a sampling manhole and a grease interceptor. They do have a sampling manhole on the West side of their parking lot next to the curb. There was not evidence of grease in the sampling manhole. I contacted the store manager, Becky Fowler, and she said that they have three (3) interceptors: one in the Bakery; one in the Deli; and one in the Meat Dept. All three interceptors are under 3 vat sinks (each vat appears to be 16"W x 20" L x 12" D). The interceptors appear to be 14-20 lb. capacity. All three (3) interceptors are cleaned monthly by Smith's Grease Trap Service.

Bob S.

*I would recommend a 40 LB. TRAP
minimum on the new 3 vat sink
and additional drains. They
should run the sizing calculations
provided by the M.E.G.R. of the
trap to see if 40 LBS. is
large enough.*

J.

MEMORANDUM

To: Gene Pabst
From: Randy Lyman
Date: January 29, 1998
Subject: Sampling manhole and adequate grease trap for the Consumers Market at 1730 S. Campbell

Bob Schaefer called me this morning as he was apparently reviewing building plans that have been submitted to the City for obtaining construction permits. He needs to know if the Consumers at this location has an adequate grease trap and sampling manhole. They are remodeling or adding-on something and if they do not have the minimum requirements, he wants to require installation of these appurtenances. He indicates that the plumbing is shown to be coming out the front of the store about midway of the building. Please check this out as soon as possible and let me know what you find out.